

Facility Summary in LAKE County in the City of ARLEE

Location: WILSON FOODS
US HIGHWAY 93 N
ARLEE, MT 59821 LAKE
Contact: Rowan Wilson, (406) 726-7777

Sys Fac ID: 24-06788
Last Inspected On: 10/10/2014
Operating Permit Renewal Date: 3/21/2018

Owners/Operators: Wilson Foods Inc, Owner
92345 US HIGHWAY 93
ARLEE MT 59821-9433
Dara Wilson, Operator (406)-745-4285 DBA WILSON FOODS
92345 US HIGHWAY 93
ARLEE MT 59821-9433
Rowan Wilson, Operator (406)-745-4285 DBA WILSON FOODS
92345 US HIGHWAY 93
ARLEE MT 59821-9433
John Carranco, UST Class A Operator
John Carranco, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	17	11/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3320			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		5/22/2014	TLS-350/Gilbarco EMC , Veeder Root		
11	17	11/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3321			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		5/22/2014	TLS-350/Gilbarco EMC , Veeder Root		
12	17	11/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3322			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		5/22/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of BIGFORK

Location: SWAN LAKE STAGE STOP INC
21385 MT HIGHWAY 83
BIGFORK, MT 59911 LAKE

Sys Fac ID: 24-05644

Last Inspected On: 10/8/2013

Operating Permit Renewal Date:

Contact: Linda Bosworth, (406) 886-2500

Owners/Operators: Mike Huddleston, Operator	(406)-886-2300	21385 MT HIGHWAY 83 SWAN LAKE MT 59911
Tracy Huddleston, Operator	(406)-886-2300	21385 MT HIGHWAY 83 SWAN LAKE MT 59911
Sell It All LLC, Owner/Operator	(406)-886-2500	23296 BOSWORTH LANE SWAN LAKE MT 59911
Linda Bosworth, UST Class A Operator		
Chris Cox, UST Class A Operator		
Tracy Gardner-Huddleston, UST Class A Operator		
Michael Huddleston, UST Class A Operator		
Linda Bosworth, UST Class B Operator		
Chris Cox, UST Class B Operator		
Tracy Gardner-Huddleston, UST Class B Operator		
Michael Huddleston, UST Class B Operator		
Thomas Pelican, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	29	5/7/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3325			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/31/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/8/2011			
2	29	5/7/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3326			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/31/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/8/2011			

Facility Summary in LAKE County in the City of BIGFORK

Location: SWAN LAKE STAGE STOP INC
21385 MT HIGHWAY 83
BIGFORK, MT 59911 LAKE

Sys Fac ID: 24-05644

Last Inspected On: 10/8/2013

Operating Permit Renewal Date:

Contact: Linda Bosworth, (406) 886-2500

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	19	7/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3327			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		3/31/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/24/2012			
4	19	7/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3328			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		3/31/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/8/2011			

Facility Summary in LAKE County in the City of BIGFORK

Location: PAPA'S WOODSBAY MARKET
14535 MT HWY 35
BIGFORK, MT 59911 LAKE

Sys Fac ID: 24-06085

Last Inspected On: 1/26/2015

Operating Permit Renewal Date: 3/28/2018

Contact: Diane Williams, (406) 837-4884

Owners/Operators: Randy Williams dba Papa's Woodsbay Market, Owner (406)-837-4884 14535 MT HIGHWAY 35
BIGFORK MT 59911
Diane Williams, Operator (406)-837-4884 14535 MT HIGHWAY 35
BIGFORK MT 59911
Randy Williams, Operator (406)-837-4884 14535 MT HIGHWAY 35
BIGFORK MT 59911
Diane Williams, UST Class A Operator
Teri Bales, UST Class B Global Operator
Shawn Kneeland, UST Class B Global Operator
Vicky Miller, UST Class B Global Operator
Tami Pasha, UST Class B Global Operator
Rod Serres, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	32	1/30/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
1279			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Not Listed	Impressed Current
Gasoline		3/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		2/2/2015	EECO 1000 , EMCO Electronics		
2	32	1/30/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
1280			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Not Listed	Impressed Current
Gasoline		3/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		2/2/2015	EECO 1000 , EMCO Electronics		

Facility Summary in LAKE County in the City of BIGFORK

Location: PAPA'S WOODSBAY MARKET
14535 MT HWY 35
BIGFORK, MT 59911 LAKE
Contact: Diane Williams, (406) 837-4884

Sys Fac ID: 24-06085
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/28/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	21	5/1/1994	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1281			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		3/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
4,000		2/2/2015	EECO 1000 , EMCO Electronics		

Facility Summary in LAKE County in the City of BIGFORK

Location: ROE HATLEN
20221 MT HIGHWAY 35
BIGFORK, MT 59911 LAKE

Sys Fac ID: 56-14137

Last Inspected On: 5/8/2014

Operating Permit Renewal Date: 7/1/2017

Contact: Kari Aiken, (406) 982-9922

Owners/Operators: Roe Hatlen, Owner (406)-982-9922 PO BOX 2825
BIGFORK MT 59911-2801
Roe Hatlen, UST Class A Operator
Roe Hatlen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	10	3/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5024		11/12/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline		3/11/2011	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
1,000					

Facility Summary in LAKE County in the City of CHARLO

Location: CHARLO SCHOOL DIST 7 J
405 2ND AVE E
CHARLO, MT 59824 LAKE

Sys Fac ID: 24-02789

Last Inspected On: 10/20/2014

Operating Permit Renewal Date: 3/27/2018

Contact: Gary Scott, (406) 644-2207

Owners/Operators: School Dist 7 J Charlo, Owner (406)-644-2207 PO BOX 10
CHARLO MT 59824-0010
Terry Wersonick, UST Class A Operator
Terry Wersonick, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	17	7/1/1998	Unknown	Flexible Plastic	
611	Yes	10/15/2014	None	Double-Walled	Yes
Currently in Use		1/1/2008	Auto Dialer	U.S. Suction	Not Applicable
Heating Oil			Deferred	Continuous Interstitial Monitor	
10,000		8/27/2012	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of CHARLO

Location: COULTER AUTOMOTIVE INC
S MAIN PO BOX 97
CHARLO, MT 59824 LAKE

Sys Fac ID: 24-04615

Last Inspected On: 7/26/2013

Operating Permit Renewal Date: 10/5/2016

Contact: Curtis Colter, (406) 644-2215

Owners/Operators: Coulter Automotive Inc, Owner (406)-644-2215 PO BOX 97
CHARLO MT 59824-0097

Sandra Coulter, UST Class A Operator
Nathan Dumont, UST Class A Operator
Sandra Coulter, UST Class B Operator
Nathan Dumont, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	20	7/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2281			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/6/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/6/2015			
4	20	7/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2282			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/6/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		3/6/2015			

Facility Summary in LAKE County in the City of CHARLO

Location: MOIESE MERCANTILE
64620 MT HIGHWAY 212
CHARLO, MT 59824 LAKE

Sys Fac ID: 24-06382

Last Inspected On: 7/29/2013

Operating Permit Renewal Date: 12/17/2016

Contact: Jesse Cheff, (406) 644-2385

Owners/Operators: Moiese Mercantile, Owner

(406)-644-2385

PO BOX 501

CHARLO MT 59824-0501

Timothy H Hall, UST Class A Operator

Leslie Muth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	16	3/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3968			None	None	Yes
Currently in Use		3/1/2009	Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
1,000		10/25/2004			

Facility Summary in LAKE County in the City of PABLO

Location: PABLO ELEMENTARY SCHOOL
608 4TH AVE
PABLO, MT 59855 LAKE

Sys Fac ID: 24-04823

Last Inspected On: 7/3/2014

Operating Permit Renewal Date: 9/25/2017

Contact: Don Arnett, (406) 676-3390

Owners/Operators: School Dist 30 Ronan, Owner (406)-644-2448 PO BOX R
RONAN MT 59864-0799
Rob Tougas, UST Class A Operator
Rob Tougas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	49	4/28/1966	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1903		5/15/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Heating Oil		6/9/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-300 , Veeder Root		

Facility Summary in LAKE County in the City of PABLO

Location: JOES JIFFY STOP
51356 US HIGHWAY 93
PABLO, MT 59855 LAKE
Contact: Margaret Bowman, (406) 676-3570

Sys Fac ID: 24-07562
Last Inspected On: 5/27/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators: Margaret M Bowman, Owner	(406)-675-3570	PO BOX 277 PABLO MT 59855
Joes Jiffy Stop Inc, Operator	(406)-675-3570	PO BOX 277 PABLO MT 59855-0277
Geneva Behnke, UST Class A Operator		
Tom Hoyt, UST Class A Operator		
Angela Talbott, UST Class A Operator		
Ezra Wilson, UST Class A Operator		
Jackie Wilson, UST Class A Operator		
Geneva Behnke, UST Class B Operator		
Tom Hoyt, UST Class B Operator		
Gail Matt, UST Class B Operator		
Angela Talbott, UST Class B Operator		
Ezra Wilson, UST Class B Operator		
Jackie Wilson, UST Class B Operator		
Gail Matt, UST Class B Global Operator		
Angela Talbott, UST Class B Global Operator		
Ezra Wilson, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	25	10/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1269			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LAKE County in the City of PABLO

Location: JOES JIFFY STOP
51356 US HIGHWAY 93
PABLO, MT 59855 LAKE
Contact: Margaret Bowman, (406) 676-3570

Sys Fac ID: 24-07562
Last Inspected On: 5/27/2015
Operating Permit Renewal Date: 10/1/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	25	10/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1270			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
5	25	10/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1271			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LAKE County in the City of PABLO

Location: QUICKSILVER EXPRESS
52001 US HIGHWAY 93
PABLO, MT 59855 LAKE
Contact: Corky Sias, (406) 675-5000

Sys Fac ID: 24-11124
Last Inspected On: 8/5/2014
Operating Permit Renewal Date: 10/25/2017

Owners/Operators: Quick Silver Express, Owner (406)-675-5000 PO BOX 278
PABLO MT 59855
Corky Sias, Operator (406)-675-5000 PO BOX 278
PABLO MT 59855
Lisa Vollin-Christensen, UST Class A Operator
Lisa Vollin-Christensen, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3296			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/2/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3297			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/2/2007	TLS-350/Gilbarco EMC , Veeder Root		
3	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3298			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/2/2007	TLS-350/Gilbarco EMC , Veeder Root		
4	04	5/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5344			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in LAKE County in the City of POLSON

Location: U OF M FLATHEAD LAKE BIOLOGICAL STATION
32125 BIO STATION LN
POLSON, MT 59860 LAKE

Sys Fac ID: 24-00507

Last Inspected On: 9/18/2014

Operating Permit Renewal Date: 1/14/2018

Contact: Mark Potter, (406) 982-3301

Owners/Operators: University of Montana Flathead Lake Biological Station, (406)-982-3301 32125 BIO STATION LANE
Owner POLSON MT 59860
Eric Anderson, UST Class A Operator
C. Eric Anderson, UST Class B Operator
Reggie Heiser, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	24	3/15/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2185			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Gasoline		9/19/2014	Manual Interstitial Monitor	MLLD Line Tightness Testing, ELLD Line Tightness Testing	
1,000		9/7/2011			
5	24	3/15/1991	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2186		10/20/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		9/19/2014	Manual Interstitial Monitor	Manual Interstitial Monitor	
2,000					

Facility Summary in LAKE County in the City of POLSON

Location: CHERRY VALLEY SCHOOL
107 8TH AVE W
POLSON, MT 59860 LAKE

Sys Fac ID: 24-02867

Last Inspected On: 9/5/2014

Operating Permit Renewal Date: 2/19/2018

Contact: Frank Clement, (406) 883-6329

Owners/Operators: School Dist 23 Polson, Owner (406)-883-6333 111 4TH AVE E
POLSON MT 59860-2132

John Hipp, UST Class A Operator
Dan Kinyon, UST Class A Operator
John Hipp, UST Class B Operator
Dan Kinyon, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	25	8/1/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1805			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Heating Oil		10/13/2011	Continuous Interstitial Monitor	Deferred	
4,000		10/13/2011	Other , Other		

Facility Summary in LAKE County in the City of POLSON

Location: MOUNTAIN WEST CO OP POLSON
808 MAIN ST
POLSON, MT 59860 LAKE

Sys Fac ID: 24-04560

Last Inspected On: 6/16/2014

Operating Permit Renewal Date: 12/2/2017

Contact: Michael Svoboda, (406) 883-5600

Owners/Operators: Mountain West Coop - Missoula, Owner (406)-543-8383 4570 N RESERVE ST
MISSOULA MT 59808-1411

Will Dukart, UST Class A Operator
Dusty Smith, UST Class A Operator
John Thompson, UST Class A Operator
John Adams, UST Class B Operator
Will Dukart, UST Class B Global Operator
Dusty Smith, UST Class B Global Operator
John Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4155		3/11/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
6	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4156		3/11/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
7	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4741		3/11/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of POLSON

Location: MOUNTAIN WEST CO OP POLSON
808 MAIN ST
POLSON, MT 59860 LAKE

Sys Fac ID: 24-04560

Last Inspected On: 6/16/2014

Operating Permit Renewal Date: 12/2/2017

Contact: Michael Svoboda, (406) 883-5600

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4648		3/11/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of POLSON

Location: POLSON BAY GROCERY 425
50451 US HIGHWAY 93
POLSON, MT 59860 LAKE
Contact: George Mahoney, (406) 571-2055

Sys Fac ID: 24-05770
Last Inspected On: 3/19/2014
Operating Permit Renewal Date: 8/9/2017

Owners/Operators: George Mahoney, Owner
Ramona Mahoney, Owner (406)-571-2055
George Mahoney, UST Class A Operator
George Mahoney, UST Class B Operator
Ramona Mahoney, UST Class B Operator

PO BOX 1127
POLSON MT 59860-1127
PO BOX 1127
POLSON MT 59860-1127

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	13	5/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4664		6/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
5	13	5/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4665		6/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
6	13	5/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4666		6/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
7	13	5/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4667		6/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of POLSON

Location: PIER 93
9 2ND AVE W
POLSON, MT 59860 LAKE
Contact: Don Miller, (406) 883-4531

Sys Fac ID: 24-05957
Last Inspected On: 4/26/2013
Operating Permit Renewal Date: 6/30/2016

Owners/Operators: Pier 93, Owner (406)-883-5768 49433 US HIGHWAY 93
POLSON MT 59860-2162
Donald Miller, UST Class A Operator
Donald Miller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	29	4/23/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1802			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		8/1/2009			
4	29	4/23/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1803			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		8/1/2009			
6	25	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1804			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		8/1/2009			

Facility Summary in LAKE County in the City of POLSON

Location: JETTE STORE
44613 US HIGHWAY 93
POLSON, MT 59860 LAKE
Contact: Gloria Schumaker, (406) 883-3861

Sys Fac ID: 24-07247
Last Inspected On: 12/1/2014
Operating Permit Renewal Date: 12/2/2017

Owners/Operators: Grits Inc, Owner (406)-883-3861 44613 US HIGHWAY 93
POLSON MT 59860-7585
Paul Bonelli, UST Class A Operator
Jeff Schumaker, UST Class A Operator
Paul Bonelli, UST Class B Operator
Jeff Schumaker, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	19	4/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1215			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TS-1000 , Incon		
5	19	4/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1216			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TS-1000 , Incon		
6	19	4/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1217			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TS-1000 , Incon		

Facility Summary in LAKE County in the City of POLSON

Location: TOWN PUMP INC POLSON
50667 US HIGHWAY 93
POLSON, MT 59860 LAKE

Contact: Roger Hovis, (406) 883-9445

Sys Fac ID: 24-08717
Last Inspected On: 1/28/2016
Operating Permit Renewal Date: 5/14/2016

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	33	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2490			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	33	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2491			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LAKE County in the City of POLSON

Location: TOWN PUMP INC POLSON
50667 US HIGHWAY 93
POLSON, MT 59860 LAKE
Contact: Roger Hovis, (406) 883-9445

Sys Fac ID: 24-08717
Last Inspected On: 1/28/2016
Operating Permit Renewal Date: 5/14/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	33	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2492			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	33	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2493			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	33	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2494			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	13	10/24/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4819			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/4/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LAKE County in the City of POLSON

Location: TOWN PUMP INC POLSON
50667 US HIGHWAY 93
POLSON, MT 59860 LAKE

Sys Fac ID: 24-08717

Last Inspected On: 1/28/2016

Operating Permit Renewal Date: 5/14/2016

Contact: Roger Hovis, (406) 883-9445

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
12	13	10/24/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4820			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/4/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LAKE County in the City of POLSON

Location: POLSON COUNTRY CLUB
111 BAYVIEW DR
POLSON, MT 59860 LAKE
Contact: Lawrence Newlin, (406) 883-2131

Sys Fac ID: 24-11824
Last Inspected On: 7/17/2013
Operating Permit Renewal Date: 11/8/2016

Owners/Operators: City of Polson, Owner (406)-883-2131 106 1ST ST E
POLSON MT 59860-2137
Patrick Nowlen, UST Class A Operator
Patrick Nowlen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	8/14/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
647			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		8/22/2013	Manual Tank Gauging	Deferred	
500					

Facility Summary in LAKE County in the City of POLSON

Location: KWATAQNUK RESORT
49708 US HIGHWAY 93
POLSON, MT 59860 LAKE

Sys Fac ID: 56-13869

Last Inspected On: 5/9/1997

Operating Permit Renewal Date:

Contact: Robert R Jr DePoe, (406) 883-3636

Owners/Operators: Confederated Salish & Kootenai Tribe, Owner

(406)-675-2700

PO BOX 278

PABLO MT 59855-0278

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	5/1/1991	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plastic Double-Walled	Ball Float Valve Yes
Currently in Use				Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000					

Facility Summary in LAKE County in the City of POLSON

Location: SAFEWAY FUEL STATION 1646
40772 MT HIGHWAY 35
POLSON, MT 59860 LAKE

Sys Fac ID: 60-15097

Last Inspected On: 10/21/2014

Operating Permit Renewal Date: 3/28/2018

Contact: Aaron Nelson, (425) 201-6301

Owners/Operators: Safeway Stores Inc, Owner

(425)-455-6545

1121 124TH AVE NE
BELLEVUE WA 98005-2101

Aaron Nelson, UST Class A Operator

Lynn Pehrson, UST Class A Operator

Heidi Morgan, UST Class B Global Operator

Cindy Stankbrook, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	07	5/22/2008	Steel Clad	Flexible Plastic	High Level Alarm
5164			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
2	07	5/22/2008	Steel Clad	Flexible Plastic	High Level Alarm
5165			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
3	07	5/22/2008	Steel Clad	Flexible Plastic	High Level Alarm
5166			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in LAKE County in the City of POLSON

Location: GOLDES
33537 MONTANA HWY 35
POLSON, MT 59860 LAKE
Contact: Elizabeth Goldes, (406) 439-0454

Sys Fac ID: 60-15208
Last Inspected On: 5/23/2013
Operating Permit Renewal Date: 5/29/2016

Owners/Operators: Elizabeth Goldes, Owner/Operator (406)-443-0454 704 STUART STREET
HELENA MT 59601
Jeffry Goldes, Owner/Operator (406)-443-0454 704 STUART STREET
HELENA MT 59601
Screna Keller, UST Class A Operator
Screna Keller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	03	5/1/2012	Aboveground Tank	Flexible Plastic	
5365	Yes	10/10/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Gasoline			Not Listed	Continuous Interstitial Monitor	
500					Yes

Facility Summary in LAKE County in the City of RAVALLI

Location: RAVALLI STORE
205 BUFFALO ST
RAVALLI, MT 59863 LAKE

Sys Fac ID: 24-09997

Last Inspected On: 7/10/2015

Operating Permit Renewal Date:

Contact: Stacy Harris, (406) 239-0655

Owners/Operators: Days Rest LLC, Owner (406)-239-0655 143 APPLE VALLEY WAY
FLORENCE MT 59833
Stacy Harris, Operator (406)-239-0655 143 APPLE VALLEY WAY
FLORENCE MT 59833
Stacy Harris, UST Class A Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	26	9/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
3464			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline		7/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
1,000					
2	26	9/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
3465			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline		7/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
1,000					
3	26	9/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
3466			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline		7/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
1,000					

Facility Summary in LAKE County in the City of ROLLINS

Location: POINTS NORTH TRADING CO
87867 US HIGHWAY 93
ROLLINS, MT 59931 LAKE

Sys Fac ID: 24-12730

Last Inspected On: 2/18/2013

Operating Permit Renewal Date: 7/22/2016

Contact: Michael Serra, (406) 250-7058

Owners/Operators: Points North of Rollins LLC, Owner (406)-250-7058 PO BOX 220
ROLLINS MT 59931
Mountain Bears Inc, Operator (406)-250-9547 22571 HWY 93 SOUTH
ROLLINS MT 59931
Thomas A Gay, UST Class A Operator
Michael Serra, UST Class A Operator
Thomas A Gay, UST Class B Operator
Michael Serra, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	6/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3095			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/26/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		10/25/2012			
2	20	6/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3096			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/26/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		10/25/2012			
3	20	6/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3097			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		10/26/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		10/25/2012			

Facility Summary in LAKE County in the City of RONAN

Location: ST LUKE COMMUNITY CLINIC- RONAN
107 6TH AVE SW
RONAN, MT 59864 LAKE

Sys Fac ID: 24-03736

Last Inspected On: 5/15/2014

Operating Permit Renewal Date: 10/16/2017

Contact: Gary Burdett, (406) 676-4441

Owners/Operators: Saint Luke Hospital, Owner/Operator (406)-676-4441 107 6TH AVE SW
RONAN MT 59864-2634

Gary Burdett, UST Class A Operator
Steven DeLay, UST Class A Operator
Nicholas Emerson, UST Class A Operator
Gary Burdett, UST Class B Operator
Steven DeLay, UST Class B Operator
Nicholas Emerson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	16	11/1/1999	Unknown	Copper	
4369	Yes		None	Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Not Listed	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: MOUNTAIN WEST CO OP RONAN
63932 US HIGHWAY 93
RONAN, MT 59864 LAKE

Sys Fac ID: 24-04530

Last Inspected On: 2/28/2014

Operating Permit Renewal Date: 7/1/2017

Contact: Dusty Smith, (406) 676-2201

Owners/Operators: Mountain West Coop - Missoula, Owner (406)-543-8383 4570 N RESERVE ST
MISSOULA MT 59808-1411

Will Dukart, UST Class A Operator
Dusty Smith, UST Class A Operator
John Thompson, UST Class A Operator
Carrie Clairmont, UST Class B Operator
Will Dukart, UST Class B Global Operator
Dusty Smith, UST Class B Global Operator
John Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	18	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2829			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		2/27/2014	TLS-350/Gilbarco EMC , Veeder Root		
10	18	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2830			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		2/27/2014	TLS-350/Gilbarco EMC , Veeder Root		
11	18	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2831			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		2/27/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: MOUNTAIN WEST CO OP RONAN
 63932 US HIGHWAY 93
 RONAN, MT 59864 LAKE
Contact: Dusty Smith, (406) 676-2201

Sys Fac ID: 24-04530
Last Inspected On: 2/28/2014
Operating Permit Renewal Date: 7/1/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
12	18	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2832			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		2/27/2014	TLS-350/Gilbarco EMC , Veeder Root		
13	18	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2833			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		2/27/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: RONAN AIRPORT
35564 RONAN AIRPORT RD
RONAN, MT 59864 LAKE

Contact: (406) 676-3461

Sys Fac ID: 24-04649

Last Inspected On: 2/23/2016

Operating Permit Renewal Date: 4/26/2016

Owners/Operators: Lake County Joint Airport Board, Owner

(406)-883-7214

LAKE COUNTY COURTHOUSE
106 4TH AVE E
POLSON MT 59860-2133

Vinson Jennison, UST Class A Operator

Vinson Jennison, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	16	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3984			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
12,000					
3	16	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3985			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
12,000					

Facility Summary in LAKE County in the City of RONAN

Location: EAST OF RONAN MIDDLE SCHOOL
200 ROUND BUTTE ROAD E
RONAN, MT 59864 LAKE

Sys Fac ID: 24-04824

Last Inspected On: 5/19/2014

Operating Permit Renewal Date: 9/13/2017

Contact: Gene Conklin, (406) 676-3390

Owners/Operators: School Dist 30 Ronan, Owner

(406)-644-2448

PO BOX R
RONAN MT 59864-0799

Rob Tougas, UST Class A Operator

Matt Gaut, UST Class B Operator

Rob Tougas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	19	8/1/1996	Fiberglass Reinforced Plastic	Copper	Flapper Valve (Auto Shutoff)
1904		4/9/2014	None	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Deferred	
10,000			TS-1000 , Incon		

Facility Summary in LAKE County in the City of RONAN

Location: ARNIES GAS AND TIRE CENTER INC
63145 US HIGHWAY 93
RONAN, MT 59864 LAKE

Sys Fac ID: 24-05517

Last Inspected On: 6/12/2014

Operating Permit Renewal Date: 8/15/2017

Contact: Kim Aipperspach, (406) 676-0400

Owners/Operators: Arnies Gas and Tire Center Inc, Owner (406)-676-0400 63145 US HIGHWAY 93
RONAN MT 59864-2808

Denise Aipperspach, UST Class A Operator
Amanda Hackman, UST Class A Operator
Denise Aipperspach, UST Class B Operator
Denise Aipperspach, UST Class B Global Operator
Amanda Hackman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	37	5/7/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3888			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		12/11/2013	TLS-350/Gilbarco EMC , Veeder Root		
5	44	5/8/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3889			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		12/11/2013	TLS-350/Gilbarco EMC , Veeder Root		
6	44	5/8/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3890			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		12/11/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: ARNIES GAS AND TIRE CENTER INC
63145 US HIGHWAY 93
RONAN, MT 59864 LAKE

Sys Fac ID: 24-05517
Last Inspected On: 6/12/2014
Operating Permit Renewal Date: 8/15/2017

Contact: Kim Aipperspach, (406) 676-0400

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	44	5/8/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3891			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		12/11/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: DYNO MART
303 US HIGHWAY 93 N
RONAN, MT 59864 LAKE

Sys Fac ID: 24-05768

Last Inspected On: 6/12/2014

Operating Permit Renewal Date: 9/9/2017

Contact: Tom Hoyt, (406) 676-3570

Owners/Operators: Joes Jiffy Stop Inc, Owner (406)-675-3570 PO BOX 277
PABLO MT 59855-0277

Tom Hoyt, UST Class A Operator
Maureen McCrea, UST Class A Operator
Tom Hoyt, UST Class B Operator
Gail Matt, UST Class B Operator
Gail Matt, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1317			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/30/2013	TLS-350/Gilbarco EMC , Veeder Root		
2	31	11/13/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1315			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/30/2013	TLS-350/Gilbarco EMC , Veeder Root		
3	31	11/13/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1316			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		7/30/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: JOHNS FUEL FARM INC
14 CLEVELAND ST SE
RONAN, MT 59864 LAKE

Contact: John Noel, (406) 676-3461

Sys Fac ID: 24-07437
Last Inspected On: 1/3/2013
Operating Permit Renewal Date: 4/26/2016

Owners/Operators: Johns Fuel Farm Inc, Owner (406)-676-3461 14 CLEVELAND ST SE
RONAN MT 59864-3027

John Noel, UST Class A Operator
Leevi Wadsworth, UST Class A Operator
Leevi Wadsworth, UST Class B Operator
John Noel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	54	4/23/1961	Cathodically Protected Steel	Steel	High Level Alarm
3394			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/3/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		12/18/2009			
2	54	4/23/1961	Cathodically Protected Steel	Steel	High Level Alarm
3395			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/3/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		12/18/2009			
3	44	4/24/1971	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3397			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/3/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
8,000		12/18/2009			

Facility Summary in LAKE County in the City of RONAN

Location: JOHNS FUEL FARM INC
14 CLEVELAND ST SE
RONAN, MT 59864 LAKE

Contact: John Noel, (406) 676-3461

Sys Fac ID: 24-07437
Last Inspected On: 1/3/2013
Operating Permit Renewal Date: 4/26/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	44	4/24/1971	Fiberglass Reinforced Plastic	Steel	High Level Alarm
3398			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Impressed Current
Gasoline		1/3/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
6,000		12/18/2009			
5	54	4/23/1961	Cathodically Protected Steel	Steel	High Level Alarm
3399			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Heating Oil		1/3/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
6,000		12/18/2009			
11	44	4/24/1971	Fiberglass Reinforced Plastic	Steel	High Level Alarm
3396			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Impressed Current
Diesel		1/3/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
8,000		12/18/2009			

Facility Summary in LAKE County in the City of RONAN

Location: TOWN PUMP INC RONAN
63459 US HIGHWAY 93
RONAN, MT 59864 LAKE

Sys Fac ID: 24-08718

Last Inspected On: 1/28/2016

Operating Permit Renewal Date: 5/14/2016

Contact: Roger Hovis, (406) 676-5290

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	43	4/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4822			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	43	4/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4823			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: TOWN PUMP INC RONAN
63459 US HIGHWAY 93
RONAN, MT 59864 LAKE
Contact: Roger Hovis, (406) 676-5290

Sys Fac ID: 24-08718
Last Inspected On: 1/28/2016
Operating Permit Renewal Date: 5/14/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	43	4/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4824			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	35	4/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4825			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
5	08	7/5/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5073			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LAKE County in the City of RONAN

Location: KICKING HORSE JOB CORPS CENTER
33091 MOLLMANN PASS TRL
RONAN, MT 59864 LAKE

Sys Fac ID: 24-10386

Last Inspected On: 5/15/1998

Operating Permit Renewal Date:

Contact: Joe Conley, (406) 644-2217

Owners/Operators: Confederated Salish & Kootenai Tribe, Owner (406)-675-2700 PO BOX 278
PABLO MT 59855-0278

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	3/27/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
			None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Manual Tank Gauging, Tank Tightness Testing, Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
1,000					
2	20	3/27/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
			None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Gasoline			Manual Tank Gauging, Tank Tightness Testing, Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
1,000					
3	20	3/27/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
			None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Manual Tank Gauging, Tank Tightness Testing, Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
1,000					

Facility Summary in LAKE County in the City of SAINT IGNATIUS

Location: SAINT IGNATIUS SCHOOL
4TH & BLAINE ST
SAINT IGNATIUS, MT 59865 LAKE

Sys Fac ID: 24-03762

Last Inspected On: 10/23/2014

Operating Permit Renewal Date: 2/26/2018

Contact: Roy Martin, (406) 745-3811

Owners/Operators: School Dist 28 Saint Ignatius, Owner

(406)-745-3811

PO BOX 1540

SAINT IGNATIUS MT 59865-1540

Stephen McCollum, UST Class A Operator

Stephen McCollum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	18	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4563		10/15/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Heating Oil		10/22/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			EECO 1500 , EMCO Electronics		

Facility Summary in LAKE County in the City of SAINT IGNATIUS

Location: ALLARDS GENERAL STORE
77579 US HIGHWAY 93 N
SAINT IGNATIUS, MT 59865 LAKE
Contact: Ken Scott, (406) 544-3433

Sys Fac ID: 24-05769
Last Inspected On: 1/7/2015
Operating Permit Renewal Date: 3/13/2018

Owners/Operators: Intermountain Oasis Inc, Owner (406)-544-3433 61574 HILLSIDE RD
SAINT IGNATIUS MT 59865
Keith Dowling, UST Class A Operator
Randy Livingston, UST Class A Operator
Kenneth Scott, UST Class A Operator
Keith Dowling, UST Class B Operator
Randy Livingston, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	10	12/1/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5042			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
10,000			TLS-300 , Veeder Root		
5	10	12/1/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5043			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
10,000			TLS-300 , Veeder Root		

Facility Summary in LAKE County in the City of SAINT IGNATIUS

Location: STUARTS SERVICE CENTER INC
240 MOUNTAIN VIEW DR
SAINT IGNATIUS, MT 59865 LAKE

Sys Fac ID: 24-10647

Last Inspected On: 9/24/2014

Operating Permit Renewal Date: 1/22/2018

Contact: (406) 745-3696

Owners/Operators: Morton & Coffman LLC, Owner (406)-745-3634 PO BOX 400
SAINT IGNATIUS MT 59865-0507
Darren Orr, UST Class A Operator
Darren Orr, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	5/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4595			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	20	5/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4596			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	20	5/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4597			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		10/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
8	00	10/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5619		10/23/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		10/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes